4 analog Input expansion screw term



Main

| Range of product | Preventa Safety automation |
|---------------------------|---|
| Product or component type | Safe input expansion module |
| Device short name | XPSMCM |
| Electrical connection | Screw terminal |
| [Us] rated supply voltage | 24 V - 2020 % DC |
| Number of inputs | 4.0 analog |
| Function of module | Analogue input current for analog input Analogue input voltage for analog input current |
| | |

Complementary

| Complementary | | |
|--------------------------------|---|--|
| Maximum power consumption in W | 3 W | |
| Power dissipation in W | 3 W | |
| Integrated connection type | Backplane expansion bus | |
| Number of terminal blocks | 4 | |
| Connections - terminals | captive screw clamp terminals, removable terminal block captive screw clamp terminals, removable terminal block | |
| Voltage state 0 guaranteed | 010 V for analog input 010 V for analog input voltage 010 V for analogue input 010 V for analogue input circuit 010 V for analogue input signals 010 V for temperature sensor | |
| Current state 0 guaranteed | 020 mA (analog input) 020 mA (analog input current) 020 mA (analogue input) 020 mA (analogue input circuit) 020 mA (analogue input signals) 020 mA (temperature sensor) | |
| Safety level | Can reach category 4 conforming to ISO 13849-1 Can reach PL = e conforming to ISO 13849-1 Can reach SIL 3 conforming to IEC 61508 SILCL 3 conforming to IEC 62061 | |
| Quality labels | CE | |
| Discrete input voltage | 24 V DC | |
| Local signalling | 1 LED green with PWR marking for power ON 1 LED green with RUN marking for RUN (status) 1 LED red with E IN marking for internal error 1 LED red with E EX marking for external error 2 LEDs orange with ADDR marking for node address 4 LEDs green/red with IN marking for input status | |
| Cable cross section | 0.21.5 Mm² - AWG 24AWG 16 flexible cablewithout cable end 0.22.5 Mm² - AWG 24AWG 14 flexible cablewithout cable end 0.251 Mm² - AWG 23AWG 18 flexible cablewith cable end, without bezel 0.252.5 Mm² - AWG 23AWG 14 flexible cablewith cable end, with bezel 0.252.5 Mm² - AWG 23AWG 14 flexible cablewith cable end, without bezel 0.51.5 Mm² - AWG 20AWG 16 flexible cablewith cable end, with double bezel 0.21 Mm² - AWG 24AWG 18 solid cablewithout cable end 0.22.5 mm² - AWG 24AWG 14 solid cablewithout cable end | |
| Mounting support | Omega 35 mm DIN rail conforming to EN 50022 | |
| Depth | 114.5 mm | |
| Height | 99 mm | |
| | | |
| Width | 22.5 mm | |

The information provided in this documentation contains general descriptions and/or technical characteristics of the performance of the products contained herein. This documentation is not inherent for and is not to be used for determining suitability or reliability of these products for specific user applications. It is the dourn and restring of the products with respect to the relevant specific application or use thereof. Neither Schneider Electric Industries SAS nor any of its affiliates or subsidiaries shall be responsible or liable for misuse of the information contained herein.

Environment

| Liviloiiiicii | | |
|--|--|--|
| Standards | IEC 62061 IEC 61508 ISO 13849-1 IEC 61800-5-1 | |
| Product certifications | RCM[RETURN]cULus[RETURN]TÜV | |
| IP degree of protection | IP20 (enclosure) | |
| Ambient air temperature for operation | -1055 °C | |
| Ambient air temperature for storage | -2085 °C | |
| Relative humidity | 1095 % | |
| Pollution degree | 2 | |
| [Uimp] rated impulse withstand voltage | 4 kV conforming to IEC 61800-5-1 | |
| Safety reliability data | PFHd = 1.53E-8 1/h DC > 99 % MTTFd = 106 years high | |
| Insulation | 250 V AC between power supply and housing conforming to IEC 61800-5-1 | |
| Overvoltage category | II | |
| Electromagnetic compatibility | Electrostatic discharge immunity test - test level: 6 kV (on contact) conforming to IEC 61000-4-2 Electrostatic discharge immunity test - test level: 20 kV (on air) conforming to IEC 61000-4-2 Susceptibility to electromagnetic fields - test level: 10 V/m (801000 MHz) conforming to IEC 61000-4-3 Susceptibility to electromagnetic fields - test level: 30 V/m (1.4 GHz2 GHz) conforming to IEC 61000-4-3 | |
| Vibration resistance | +/-0.35 mm (f= 1055 Hz) conforming to IEC 61496-1 | |
| Shock resistance | 10 gn (duration = 16 ms) for 1000 shocks on each axis conforming to IEC 61496-1 | |
| Service life | 20 year(s) | |
| | | |

Packing Units


| . doming office | |
|------------------------------|----------|
| Unit Type of Package 1 | PCE |
| Number of Units in Package 1 | 1 |
| Package 1 Height | 4.6 cm |
| Package 1 Width | 12.7 cm |
| Package 1 Length | 16.2 cm |
| Package 1 Weight | 259.0 g |
| Unit Type of Package 2 | S03 |
| Number of Units in Package 2 | 26 |
| Package 2 Height | 30.0 cm |
| Package 2 Width | 30.0 cm |
| Package 2 Length | 40.0 cm |
| Package 2 Weight | 7.327 kg |
| | |

Offer Sustainability

| REACh Regulation | REACh Declaration | |
|----------------------------|---|--|
| REACh free of SVHC | Yes | |
| EU RoHS Directive | Pro-active compliance (Product out of EU RoHS legal scope) | |
| Mercury free | Yes | |
| China RoHS Regulation | China RoHS Declaration | |
| RoHS exemption information | ₽¥Yes | |
| WEEE | The product must be disposed on European Union markets following specific waste collection and never end up in rubbish bins | |

Dimensions


Screw Terminal



4.5

Mounting Safety Controller CPU with Module(s)

Mount BackPlane Connector on Rail








- 1 : Connect as much Backplane Connector as module to be install.
- 2 : Fix the connectors to the rail (Top first).

Mount Safety Controller CPU with Other Module(s)








- 1: Mount controller CPU and modules on rail.
- $2: \\ Make sure that the controller CPU or the module(s) are plugged on the BackPlane connector.$

Wiring

Terminal Designation




| Terminal | Signal | Description |
|----------|------------|----------------------|
| 1 | 24 VDC | 24 Vdc power supply |
| 2 | NODE_ADDR0 | Node selection |
| 3 | NODE_ADDR0 | |
| 4 | 0 VDC | 0 Vdc power supply |
| 9 | 24VDC_S1 | Sensor 1 connections |
| 10 | IN_S1 | |
| NEG_S1 | | |
| 11 | OUT_S1 | |
| POS_S1 | | |
| 12 | 0 VDC_S1 | |
| 13 | 24VDC_S3 | Sensor 3 connections |
| 14 | IN_S3 | |
| NEG_S3 | | |
| 15 | OUT_S3 | |
| POS_S3 | | |
| 16 | 0 VDC_S3 | |
| 17 | 24VDC_S2 | Sensor 2 connections |
| 18 | IN_S2 | |
| NEG_S2 | | |
| 19 | OUT_S2 | |
| POS_S2 | | |
| 20 | 0 VDC_S2 | |
| 21 | 24VDC_S4 | Sensor 4 connections |
| 22 | IN_S4 | |
| NEG_S4 | | |
| 23 | OUT_S4 | |
| POS_S4 | | |

| Terminal | Signal | Description |
|----------|----------|-------------|
| 24 | 0 VDC_S4 | |


Wiring Example

2 Wires Current Sensor




(1): Sensor

3 Wires Current Sensor




(1): Sensor

4 Wires Current Sensor



(1): Sensor

3 Wires Voltage Sensor



(1): Sensor