Product data sheet Characteristics

XPSMCMDI0800G

expansion module, Modicon MCM, 8 inputs, spring



Main Range of product Preventa Safety automation Product or component Safe input expansion module type Device short name XPSMCM Spring terminal Electrical connection [Us] rated supply 24 V - 20...20 % DC voltage Number of inputs 8 digital Number of outputs 4 test for line control Discrete input type PNP PNP Discrete output type Function of module Monitoring safety detection for discrete input Monitoring safety dialogue for discrete input

Complementary

Maximum power consumption in W	3 W
Power dissipation in W	3 W
Integrated connection type	Backplane expansion bus
Number of terminal blocks	4
Connections - terminals	spring clamp terminals, removable terminal block spring clamp terminals, removable terminal block
Safety level Can reach category 4 conforming to ISO 13849-1 Can reach PL = e conforming to ISO 13849-1 Can reach SIL 3 conforming to IEC 61508 SILCL 3 conforming to IEC 62061	
Quality labels	CE
Discrete input voltage	24 V DC
Local signalling	1 LED green with PWR marking for power ON 1 LED green with RUN marking for RUN (status) 1 LED red with E IN marking for internal error 1 LED red with E EX marking for external error 2 LEDs orange with ADDR marking for node address 8 LEDs yellow with IN marking for input status
Cable cross section	0.22.5 Mm² - AWG 24AWG 14 flexible cablewithout cable end 0.252.5 Mm² - AWG 23AWG 14 flexible cablewith cable end, with bezel 0.252.5 Mm² - AWG 23AWG 14 flexible cablewith cable end, without bezel 0.22.5 Mm² - AWG 24AWG 14 solid cablewithout cable end 0.51 mm² - AWG 20AWG 18 flexible cablewith cable end, with double bezel
Mounting support	Omega 35 mm DIN rail conforming to EN 50022
Depth	22.5 mm
Height	99 mm
Width	114.5 mm
Net weight	0.23 kg

Environment

Z. T. T. G. T. T. G. T.	
Standards	IEC 61508 ISO 13849-1 IEC 61800-5-1 IEC 62061
Product certifications	TÜV[RETURN]RCM[RETURN]cULus
IP degree of protection	IP20 (enclosure)
Ambient air temperature for operation	-1055 °C
Ambient air temperature for storage	-2085 °C
Relative humidity	1095 %
Pollution degree	2
[Uimp] rated impulse withstand voltage	4 kV conforming to IEC 61800-5-1
Safety reliability data	PFHd = 5.75E-9 1/h DC > 99 % MTTFd < 100 years high
Insulation	250 V AC between power supply and housing conforming to IEC 61800-5-1
Overvoltage category	II
Electromagnetic compatibility	Electrostatic discharge immunity test - test level: 6 kV (on contact) conforming to IEC 61000-4-2 Electrostatic discharge immunity test - test level: 20 kV (on air) conforming to IEC 61000-4-2 Susceptibility to electromagnetic fields - test level: 10 V/m (801000 MHz) conforming to IEC 61000-4-3 Susceptibility to electromagnetic fields - test level: 30 V/m (1.4 GHz2 GHz) conforming to IEC 61000-4-3
Vibration resistance	+/-0.35 mm (f= 1055 Hz) conforming to IEC 61496-1
Shock resistance	10 gn (duration = 16 ms) for 1000 shocks on each axis conforming to IEC 61496-1
Service life	20 year(s)
-	

Packing Units

I acking Office	
Unit Type of Package 1	PCE
Number of Units in Package 1	1
Package 1 Height	4.5 cm
Package 1 Width	12.8 cm
Package 1 Length	16.3 cm
Package 1 Weight	222.0 g
Unit Type of Package 2	S01
Number of Units in Package 2	6
Package 2 Height	15.0 cm
Package 2 Width	15.0 cm
Package 2 Length	40.0 cm
Package 2 Weight	1.579 kg

Offer Sustainability


REACh Regulation	REACh Declaration
REACh free of SVHC	Yes
EU RoHS Directive	Pro-active compliance (Product out of EU RoHS legal scope)
Mercury free	Yes
China RoHS Regulation	China RoHS Declaration
RoHS exemption information	₽
WEEE	The product must be disposed on European Union markets following specific waste collection and never end up in rubbish bins
PVC free	Yes

XPSMCMDI0800G

Dimensions

Spring Terminal






XPSMCMDI0800G

Mounting Safety Controller CPU with Module(s)

Mount BackPlane Connector on Rail








- 1 : Connect as much Backplane Connector as module to be install.
- 2 : Fix the connectors to the rail (Top first).

Mount Safety Controller CPU with Other Module(s)








- 1: Mount controller CPU and modules on rail.
- $2: \\ Make sure that the controller CPU or the module(s) are plugged on the BackPlane connector.$

XPSMCMDI0800G


Wiring

Terminal Designation



Terminal	Signal	Description
1	24 VDC	24 Vdc power supply
2	NODE_ADDR0	Node selection
3	NODE_ADDR1	
4	0 VDC	0 Vdc power supply
5	INPUT1	Digital input 1
6	INPUT2	Digital input 2
7	INPUT3	Digital input 3
8	INPUT4	Digital input 4
9	OUT_TEST1	Short circuit detected output
10	OUT_TEST2	
11	OUT_TEST3	
12	OUT_TEST4	
13	INPUT5	Digital input 5
14	INPUT6	Digital input 6
15	INPUT7	Digital input 7
16	INPUT8	Digital input 8

Wiring Example



a : Emergency stop

b : Light curtain